

Document Title: Certificate of Conformity PTS-63A~PTS-6300A	Date of Issue: 11/08/2011
---	------------------------------

SAPO CERTIFICATION & TESTING LABORATORY



CERTIFICATE OF CONFORMITY

EU -LOW VOLTAGE DIRECTIVE- 2006/95/EC
NO.: SP1001GZ1111414

Applicant: POWERCITY ELECTROMECHANICAL & EQUIPMENT CO.,LTD

Applicant Address: LAICUO INDUSTRIAL ZONE,XIYUAN SIDE,JINJIANG CITY,FUJIAN, CHINA

Product Description: AUTOMATIC TRANSFER SWITCH

Model : PTS-63A~PTS-6300A

Parameters:

Rated Voltage:	DC 8.0V~35.0V Power Supply Constantly ≤ 690V
Rated Frequency:	50Hz/ 60Hz
Power Consumption:	<3W (Standby Mode: ≤ 2W)

Complies with the requirements of the European Community Directive 2006/95/EC. The submitted products have been tested by us with the listed standards and found in compliance with the following European Standards:

EN 60947-1:2007

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence applicant's disposal. This certificate does not imply assessment of the series-production of the product. The CE markings as shown below can be affixed on the product after preparation of necessary technical documentation.




Helen

Authorized by: _____
Chief Assessor 8 November 2011

SAPO CERTIFICATION & TESTING LABORATORY LIMITED
THIS CERTIFICATE REFLECTS THE FINDINGS OF THE TIME AND PLACE OF THE AUDIT
THE CERTIFICATION IS ONLY VALID WITH THE TEST REPORT TECHNICAL CONSTRUCTION FILE
Internet site: www.sapo.org.uk

**CERTIFICATE OF CONFORMITY**

EU EMC-DIRECTIVE 2004/108/EC

NO.: SP1001GZ1111415

Applicant: POWERCITY ELECTROMECHANICAL & EQUIPMENT CO.,LTD

Applicant Address: LAICUO INDUSTRIAL ZONE,XIYUAN SIDE,JINJIANG CITY,FUJIAN,
CHINA

Product Description: AUTOMATIC TRANSFER SWITCH

Model : PTS-63A ~PTS-6300A

Complies with the requirements of the European Community Directive 2004/108/EC. The submitted products have been tested by us with the listed standards and found in compliance with the following European Standards:

EN 55011:2007+A2:2007,EN 61000-4-2/3/4/5/6/8/11

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence applicant's disposal. This certificate does not imply assessment of the series-production of the product. The CE markings as shown below can be affixed on the product after preparation of necessary technical documentation.



Authorized by: Helen
Chief Assessor 8 November 2011

SAPO CERTIFICATION & TESTING LABORATORY LIMITED

THIS CERTIFICATE REFLECTS THE FINDINGS OF THE TIME AND PLACE OF THE AUDIT
THE CERTIFICATION IS ONLY VALID WITH THE TEST REPORT TECHNICAL CONSTRUCTION FILE
Internet site: www.sapo.org.uk

Applicable Directives:

LVD 2006/95/EC – Low Voltage Directive

EMC 2004/108/EC – Electromagnetic Compatibility Directive

Applicable Standards:

EN 60947-1:2007 – Low Voltage Switchgear and Controlgear; Part 1 – General Rules.

EN 55011:2007+A2:2007 - Industrial, Scientific and Medical Equipment - Radio-Frequency Disturbance Characteristics - Limits and Methods of Measurement.

EN 61000-4-2 – Electrostatic Discharge Immunity Test.

EN 61000-4-3 – Radiated Radio-Frequency, Electromagnetic Field Immunity Test.

EN 61000-4-4 – Electrical Fast Transient / Burst Immunity Test.

EN 61000-4-5 – Lightning / Surge Immunity.

EN 61000-4-6 – Testing and Measurement Techniques – Immunity to Conducted Disturbances, Induced by Radio-Frequency Fields.

EN 61000-4-8 – Testing and Measurement Techniques – Power Frequency Magnetic Field Immunity Test.

EN 61000-4-11 – Testing and Measurement Techniques – Voltage Dips, Short Interruptions and Voltage Variations Immunity Tests.

